

1814 Franklin St, Suite 501 Oakland, CA 94612

TECHNICAL MEMORANDUM

To: John Ricker and Ron Duncan

From: Georgina King and Cameron Tana

Date: March 31, 2017

Subject: Santa Cruz Mid-County Basin Groundwater Flow Model: Water Use Estimates and Return Flow Implementation (Task 2)

Contents

| 1.0 | Introduction |
|-----|---|
| 2.0 | Non-Municipal Domestic Water Use |
| 2.1 | Non-Municipal Domestic Water Use Methodology3 |
| 2.2 | Non-Municipal Domestic Water Use Factor7 |
| 2.3 | Non-Municipal Domestic Water Use Estimate10 |
| 2.4 | Monthly Variation of Non-Municipal Domestic Water Use |
| 3.0 | Institutional Non-Municipal Water Use |
| 3.1 | Calculation of Irrigation Use12 |
| 4.0 | Agricultural Water Use |
| 4.1 | Agricultural Irrigation Use Methodology16 |
| 4.2 | Preliminary Agricultural Irrigation Demand Estimate17 |
| 5.0 | Implementing Non-Municipal Pumping in Model |
| 6.0 | Simulating Return Flow Components |
| 6.1 | Water System Losses |
| 6.2 | Wastewater Return Flows 21 |
| 6.3 | Irrigation Return Flows |
| 7.0 | Calculating Return Flow Components |
| 7.1 | Municipal Return Flow 23 |
| 7.2 | Non-Municipal Domestic Return Flow |

| 7.3 | Institutional Non-Municipal Irrigation Return Flow | 25 |
|-----|--|----|
| 7.4 | Agricultural Irrigation Return Flow | 25 |
| 8.0 | Sensitivity of Water Use and Return Flow Assumptions | 26 |
| 9.0 | References | 27 |

Appendix A - Santa Cruz County Land Use Codes

List of Figures

| Figure 1: Non-Municipal Water Use Building Footprints and Residential Parcels | 6 |
|---|----|
| Figure 2: Non-Municipal Groundwater Use Institutions | 15 |
| Figure 3: 2014 Agriculture in the Model Area | 19 |
| Figure 4: Approach to Estimating Municipal Return Flow | 23 |
| Figure 5: Municipal Applied Water Areas | 24 |
| Figure 6: Approach for Estimating Non-Municipal Domestic Return Flow | 25 |
| Figure 7: Return Flow Estimate Approach from Irrigation per Model Cell | 26 |

List of Tables

| Table 1: Summary of Non-Municipal Water Use Residential Building Count | 5 |
|--|-------|
| Table 2: Groundwater Pumped by Small Water Systems in 2015 | 7 |
| Table 3: Observed Conservation from 2013 through 2015 for Small Water System v | with |
| Metered Records | 8 |
| Table 4: Summary of Non-Municipal Water Use Factors | 9 |
| Table 5: Estimated Non-Municipal Domestic Water Use based on Number of Resider | ntial |
| Buildings and Population Change | 11 |
| Table 6: Estimated Groundwater Pumped by Institutions/Facilities in the Model Area | a 14 |
| Table 7: Monthly Crop Coefficients (Kc) | 16 |
| Table 8: Summary of 2014 Agricultural Water Demand | 18 |
| Table 9: Summary of Packages Used to Simulate Return Flow in the Model | 21 |
| | |

1.0 INTRODUCTION

This technical memorandum documents the methodologies used for estimating the nonmunicipal water use component of consumptive use in the basin for input into the Santa Cruz Mid-County basin groundwater model that simulates conditions for Water Years 1985-2015. The components of consumptive use are water use and return flow. Water use estimates are required to estimate groundwater pumping where pumping is not metered or recorded. Water use estimates are also required to estimate return flow, the water used but then returned to the watershed. Watershed processes simulated by the Precipitation Runoff Modeling System (PRMS) will be integrated into the groundwatersurface water model using GSFLOW. An introductory discussion of the approach for estimates for return flow are also discussed in this memorandum.

Municipal pumping within the basin is metered, but for most areas without municipal supplies the amount of water use is not metered or recorded. For these non-metered areas, the amount of water use is estimated based on land use. The estimates for non-municipal domestic water use is described in this memorandum. The methodology for estimating institutional, recreational, and agricultural irrigation water use based on crop type and climate is also described in this memorandum. These estimates of water use will be used to define non-municipal pumping in the model.

The technical memorandum describes a number of assumptions for water use and return flow that will be incorporated into the Mid-County Groundwater Basin groundwater model. The sensitivity of these assumptions will be tested by the model. However, the amount of non-municipal domestic, institutional, recreational, and agricultural water use is small and likely less sensitive compared to some of the other model inputs, such as precipitation, and outputs, such as evapotranspiration.

2.0 NON-MUNICIPAL DOMESTIC WATER USE

2.1 NON-MUNICIPAL DOMESTIC WATER USE METHODOLOGY

For purposes of the groundwater model, non-municipal water use is considered use that is supplied by non-municipal sources of groundwater. Community water systems are included in the non-municipal water use estimate where metered data are not available. Non-municipal water use estimates are used for two purposes: to provide a volume for groundwater extraction where metered data are not available, and to estimate the amount of non-municipal use return flow from septic tanks and landscape irrigation as a proportion of the water used at each residence. Commercial water use is not considered in this estimate because according to Santa Cruz County's (the County's) 1994 land use dataset, there is no significant commercial land use, other than agriculture-related activities, in areas that do not receive municipal water supply. To estimate the amount of non-municipal domestic water use within the model domain, two sources of data are used. The primary data source is the County's building footprint geographical information systems (GIS) layer that is used to identify individual residential buildings. The second data source, used to supplement the building footprints, is land use data from Santa Cruz County identifying residential parcels. Santa Cruz County developed the building footprint layer from aerial photograph interpretation using photographs from 2003 and 2007. We applied a filter to exclude buildings that are not classed as habitable structures and have footprints that are less than 500 square feet in area. Residential buildings served by the City of Santa Cruz, Soquel Creek Water District (SqCWD), Central Water District (CWD), City of Watsonville, and Scotts Valley Water District were also excluded. To identify residential buildings served by the list of agencies above, a layer of municipal metered parcels was intersected with the building footprints. All residential building footprints falling within the metered parcel layer or that were part of a multi-parcel residential complex that included one metered parcel were excluded following the assumption that these residences are supplied water by an overlying water supply agency.¹

Because the building footprint data comprises only residential buildings as of 2007, and because some buildings may have been missed in the County's building footprint layer due to tree cover, we also identified residential parcels that do not receive municipal supply and did not have an identified building footprint from Santa Cruz County's land use dataset. Residential parcels added to the dataset were selected using land use codes listed in Appendix A. Residential parcels not receiving municipal water were identified based on the layer of metered parcels. In order to determine the number of non-municipal water use residential buildings as of 2014, we assumed that each residential parcel without an identified building footprint had one building unless the land use description for the parcel specifically included the number of additional residences.

Table 1 shows the number of non-municipal water use residential buildings as of 2014 in the full model domain and within the Santa Cruz Mid-County Basin. The table also breaks down the number of non-municipal water use homes that are on septic and sewer. Sewered areas are those areas which are connected to sewer lines. The sewer spatial data was provided by the County and SqCWD. It is assumed that those homes not connected to the sewer are on septic systems.

¹ Central Water District does provide water to a few residences that also have private wells; those wells are seasonal and/or not reliable sources of drinking water (Bracamonte, 2016). Therefore, this small amount of private water use is not accounted for in the model. This same assumption was made for other areas supplied municipal water by other agencies.

| | Number of N Water Use Ho Syst | on-Municipal mes on Septic œms | Number of N Water Use Ho | on-Municipal mes on Sewer | Total Number of Non- Municipal Water Use Homes | | |
|--|-------------------------------------|--------------------------------------|-----------------------------|------------------------------------|---|------------------------------------|--|
| Data Source | Model Area | Mid-County Groundwater Basin | Model Area | Mid-County Groundwater Basin | Model Area | Mid-County Groundwater Basin | |
| Santa Cruz County Building Footprints | 4,333 | 1,728 | 409 | 331 | 4,742 | 2,059 | |
| Santa Cruz County Land Use Residential Parcels Without Building Footprints | 736 | 326 | 0 | 0 | 736 | 326 | |
| Total | 5,069 | 2,054 | 409 | 331 | 5,478 | 2,385 | |

Table 1: Summary of Non-Municipal Water Use Residential Building Count

Page 6



Figure 1: Non-Municipal Water Use Building Footprints and Residential Parcels

HydroMetrics Water Resources Inc. • 1814 *Franklin Street, Suite* 501 • Oakland, CA 94612 (510) 903-0458 • (510) 903-0468 (fax)

2.2 NON-MUNICIPAL DOMESTIC WATER USE FACTOR

An annual water use factor was developed to apply to the total number of non-municipal water use residences to obtain annual volumes of non-municipal groundwater pumped within the model area. The water use factor for 2015 was based on an evaluation of water use in 2015 by small water systems within and in close proximity to the model area (Table 2). From these data provided by the County, it was observed that water use per connection is greater for the larger of the small water systems in the Pajaro Valley Groundwater Sub-basin (Table 2). Based on this, the average 2015 water use factor for small water systems in the Pajaro Valley Groundwater Sub-basin is 0.50 acre-feet per year, and in the Mid-County Groundwater Basin (and remaining area within the model) it is 0.23 acre-feet per year (Table 2). These factors are applied to the non-municipal domestic dataset for Water Year 2015 according to the groundwater basin the water use falls in.

| Small System Name | Connections | 2015 Use (gallons) | 2015 Use / Connection (gallons) | 2015 Water Use Factor (AFY) |
|---------------------------------|-------------|-----------------------|---------------------------------------|-----------------------------------|
| Allan Lane Water Association | 16 | 4,326,708 | 270,419 | 0.83 |
| Aptos Hills Mutual Water Co. | 11 | 2,514,698 | 228,609 | 0.70 |
| Aptos Ridge Mutual Water Co. | 16 | 3,375,425 | 210,964 | 0.65 |
| Larkin Ridge Mutual Water Co. | 5 | 329,270 | 65,854 | 0.20 |
| Milky Way Mutual Water Co. | 9 | 420,975 | 46,775 | 0.14 |
| Trout Gulch Mutual | 186 | 13,754,865 | 73,951 | 0.23 |
| Purisima Mutual Water Co. | 14 | 1,767,174 | 126,227 | 0.39 |
| PureSource Water Inc. | 80 | 5,315,289 | 66,441 | 0.20 |
| Jarvis Mutual Water Co. | 36 | 2,143,690 | 59,547 | 0.18 |
| Laurel Community League | 24 | 1,283,012 | 53,459 | 0.16 |
| Average All | | | | 0.37 |
| Average Mid-County Basin | | | | 0.23 |
| Average Pajaro Valley Sub-basin | | | | 0.50 |

Table 2: Groundwater Pumped by Small Water Systems in 2015

Five top small water systems in the table (in bold italics) are located in the Pajaro Valley Groundwater Subbasin.

The water use factor was assumed to have been higher in years prior to 2015 because water conservation was not practiced to the extent that it is in the most recent years as evidenced by water use metered at several systems with data from 2013 through 2015 (Table 3). Based on this, percentage of water conserved between 2013 and 2015 in Pajaro Valley Groundwater Sub-basin was 20%, and in the Mid-County Groundwater Basin

(and remaining area within the model) it was 34% (Table 2). These factors are applied to the 2015 water use factor to arrive at a water use factor for 2013. Water Year 2014's water use factor was assumed to be the mean of 2013 and 215 factors.

The water use factors are increased incrementally from 2013 backwards to the start of the model period. For the non-Pajaro Valley Groundwater Sub-basin areas, the period from 1989 through 2004 is assigned a water use factor 0.44 acre-feet per year based on Wolcott (1999), with a higher factor before that period and a declining factor since that period. For the Pajaro Valley Groundwater Sub-basin, a Proposition 218 service charge study by PVWMA estimated a water use factor of 0.59 acre-feet per year for 2009 based on small water system usage. This water use factor is the same as that estimated for 2015 based on 20% conservation of 2015 use, and thus was applied from 2009 through 2013. The water use factors prior to 2009 were increased incrementally over the same periods as the non-Pajaro Valley Groundwater Sub-basin factors. Table 4 provides the annual water use factors used to estimate historical non-municipal water use for the model area and for the Mid-County Groundwater Basin, as a subset of the model area.

| Small Water System | July – | December ((AFY) | Conservation % 2013 – 2015 | |
|---------------------------------|--------|---------------------|-------------------------------|--------------|
| | 2013 | 2014 | 2015 | WUF (AFY) |
| Aptos Hills Mutual Water Co. | 4.3 | 6.5 | 3.5 | 17% |
| Aptos Ridge Mutual Water Co. | 9.0 | 3.5 | 6.9 | 23% |
| Trout Gulch Mutual | 36.0 | 24.3 | 21.7 | 40% |
| PureSource Water Inc. | 11.7 | 7.9 | 8.6 | 27% |
| Jarvis Mutual Water Co. | 6.2 | 5.1 | 2.2 | 65% |
| Laurel Community League | 2.0 | 2.0 | 1.9 | 4% |
| Average All | | | | 29% |
| Average Mid-County Basin | | | | 34% |
| Average Pajaro Valley Sub-basin | | | | 20% |

Table 3: Observed Conservation from 2013 through 2015 for Small Water System withMetered Records

| | Non-Pajaro Valley | Non-Pajaro Valley |
|--------------------------|-------------------|-------------------|
| | Groundwater Sub- | Groundwater Sub- |
| T AT 4 B / | Basin | Basin |
| Water Year | (AFY) | (AFY) |
| 1985 | 0.46 | 0.62 |
| 1986 | 0.46 | 0.62 |
| 1987 | 0.46 | 0.62 |
| 1988 | 0.46 | 0.62 |
| 1989 | 0.44 | 0.62 |
| 1990 | 0.44 | 0.62 |
| 1991 | 0.44 | 0.62 |
| 1992 | 0.44 | 0.62 |
| 1993 | 0.44 | 0.62 |
| 1994 | 0.44 | 0.62 |
| 1995 | 0.44 | 0.62 |
| 1996 | 0.44 | 0.62 |
| 1997 | 0.44 | 0.62 |
| 1998 | 0.44 | 0.62 |
| 1999 | 0.44 | 0.62 |
| 2000 | 0.44 | 0.62 |
| 2001 | 0.44 | 0.62 |
| 2002 | 0.44 | 0.62 |
| 2003 | 0.44 | 0.62 |
| 2004 | 0.44 | 0.62 |
| 2005 | 0.41 | 0.61 |
| 2006 | 0.41 | 0.61 |
| 2007 | 0.41 | 0.61 |
| 2008 | 0.41 | 0.61 |
| 2009 | 0.38 | 0.59 |
| 2010 | 0.38 | 0.59 |
| 2011 | 0.38 | 0.59 |
| 2012 | 0.38 | 0.59 |
| 2013 | 0.35 | 0.59 |
| 2014 | 0.29 | 0.54 |
| 2015 | 0.23 | 0.5 |

Table 4: Summary of Non-Municipal Water Use Factors

2.3 NON-MUNICIPAL DOMESTIC WATER USE ESTIMATE

To estimate the annual non-municipal water use for all simulated years of the model period, the number of non-municipal residences was extrapolated from the count of residential buildings for 2014 obtained from Santa Cruz County building footprints and residential parcels. The number of buildings was assumed to increase or decrease in proportion to the increase or decrease in the County's unincorporated population relative to 2014's population (Table 5). Spatial distribution of water use was maintained consistent to the distribution for 2014.

Table 5 shows that estimates of annual non-municipal residential groundwater use in the model area have ranged from approximately 2,751 acre-feet in 1985 to a maximum of 3,223 acre-feet in 2000, subsequently falling to a minimum of 2,418 acre-feet in 2015. A subset of non-municipal estimates of groundwater use for the Santa Cruz Mid-County Basin are included in Table 5.

2.4 MONTHLY VARIATION OF NON-MUNICIPAL DOMESTIC WATER USE

Pumping will be applied to the model in monthly stress periods because municipal pumping for Water Years 1985-2015 is recorded on a monthly basis. Monthly variation of non-municipal domestic water use is assumed to result from variation in outdoor water use. Outdoor water use is assumed to average 30% of total domestic water use (Johnson *et al.*, 2004). The variation of outdoor water use by month will be estimated from the variation of potential evapotranspiration (PET) minus actual evapotranspiration of rainfall as calculated by an initial simulation of watershed processes by PRMS.

Table 5: Estimated Non-Municipal Domestic Water Use based on Number ofResidential Buildings and Population Change

| | TI.' | Estimated Na Municipa Residentia | umber of Non- al Supplied al Buildings Mid-County | Non-Municipal Domestic Water Use (AFY) — Mid-County | | | |
|-------|------------|--|--|--|-------------|--|--|
| Wator | Denulation | | Groundwater | | Groundwater | | |
| Year | % of 2014 | Model Area | Basin | Model Area | Basin | | |
| 1985 | 90.1% | 4,938 | 2,147 | 2,880 | 988 | | |
| 1986 | 92.1% | 5,046 | 2,194 | 2,943 | 1,009 | | |
| 1987 | 94.0% | 5,148 | 2,239 | 3,003 | 1,030 | | |
| 1988 | 94.8% | 5,194 | 2,259 | 3,029 | 1,039 | | |
| 1989 | 96.5% | 5,289 | 2,300 | 3,060 | 1,012 | | |
| 1990 | 98.3% | 5,383 | 2,341 | 3,115 | 1,030 | | |
| 1991 | 97.3% | 5,329 | 2,317 | 3,084 | 1,019 | | |
| 1992 | 97.8% | 5,357 | 2,330 | 3,100 | 1,025 | | |
| 1993 | 98.5% | 5,398 | 2,347 | 3,124 | 1,033 | | |
| 1994 | 99.3% | 5,439 | 2,365 | 3,147 | 1,041 | | |
| 1995 | 99.6% | 5,456 | 2,372 | 3,157 | 1,044 | | |
| 1996 | 100.2% | 5,489 | 2,387 | 3,176 | 1,050 | | |
| 1997 | 99.5% | 5,449 | 2,370 | 3,153 | 1,043 | | |
| 1998 | 100.1% | 5,483 | 2,384 | 3,173 | 1,049 | | |
| 1999 | 100.7% | 5,518 | 2,399 | 3,193 | 1,056 | | |
| 2000 | 101.7% | 5,570 | 2,422 | 3,223 | 1,066 | | |
| 2001 | 100.4% | 5,500 | 2,392 | 3,183 | 1,052 | | |
| 2002 | 99.9% | 5,472 | 2,379 | 3,166 | 1,047 | | |
| 2003 | 99.1% | 5,429 | 2,361 | 3,142 | 1,039 | | |
| 2004 | 98.0% | 5,368 | 2,334 | 3,106 | 1,027 | | |
| 2005 | 96.7% | 5,298 | 2,304 | 2,988 | 945 | | |
| 2006 | 96.5% | 5,287 | 2,299 | 2,982 | 943 | | |
| 2007 | 96.2% | 5,270 | 2,292 | 2,973 | 940 | | |
| 2008 | 96.8% | 5,305 | 2,307 | 2,992 | 946 | | |
| 2009 | 97.3% | 5,333 | 2,319 | 2,882 | 881 | | |
| 2010 | 97.8% | 5,360 | 2,331 | 2,897 | 886 | | |
| 2011 | 97.9% | 5,364 | 2,332 | 2,899 | 886 | | |
| 2012 | 98.4% | 5,392 | 2,344 | 2,914 | 891 | | |
| 2013 | 99.3% | 5,439 | 2,365 | 2,900 | 824 | | |
| 2014 | 100.0% | 5,478 | 2,382 | 2,660 | 689 | | |
| 2015 | 100.8% | 5,520 | 2,400 | 2,418 | 552 | | |
| | | | Average | 3,021 | 970 | | |

Note: estimates based on estimated 2014 residential building/parcel count and 2014 unincorporated population

3.0 INSTITUTIONAL NON-MUNICIPAL WATER USE

Non-municipal, non-agricultural water use that is excluded from non-municipal domestic water use, because it cannot be accounted for by using residential buildings or parcels, is considered institutional non-municipal water use. This is water use by institutions or facilities within the model area that pump their own groundwater primarily for large scale irrigation of recreational turf.

The only small water system in the model area with available and consistent historical usage records is from Trout Gulch Mutual, where data are available from 2008 through 2015. This usage is included as institutional use because it is not supplied by municipal water and does not need to be estimated based on residential building footprints or parcels. Pumping for Trout Gulch Mutual prior to 2008 was assumed to be the same as its 2008 pumping. Estimates of pumping by other small water systems who do not have available and well-documented multi-year records of usage were developed by using the building footprints, parcels and water use factors described in Section 2.0.

Table 6 lists the non-municipal and non-agricultural water use institutions/facilities and provides their estimated water use. Estimates of water use are from a number of sources as referenced in the table. Figure 2 shows the locations of these institutions within the model area.

3.1 CALCULATION OF IRRIGATION USE

Some of the institutions use privately pumped groundwater to irrigate recreational turf in addition to potable supply for their institutions. Table 6 identifies areas of irrigation for these institutions. The amount of groundwater pumped for outdoor use based on the turf acreage provided will be estimated based on potential evapotranspiration (PET) minus rainfall evapotranspiration (ET demand) calculated by an initial simulation of watershed processes by PRMS that accounts for climatic conditions during the 1985-2015 model period. ET calculated by PRMS is for generalized plant cover, while the estimated irrigation for turf is based on crop evapotranspiration specific to turf (ET_c). ET_c is estimated by multiplying turfgrass' crop coefficient (K_c) by ET demand calculated by PRMS adjusted for the generalized crop coefficient applied in PRMS. Values of K_c for turf vary by month and are listed in Table 7. An irrigation inefficiency of 10-20% will be added to irrigation demand to estimate the pumping needed to meet this demand. Although PRMS calculates soil moisture that could affect irrigation demand, to avoid iterative calculation of irrigation demand using the model, we will estimate irrigation demand based only on ET_c minus actual evapotranspiration of rainfall calculated by PRMS adjusted for crop coefficients.

Table 6 also shows a preliminary estimate for outdoor water use at these areas prior to running the model using average monthly reference potential evapotranspiration (ET_{0}) from CIMIS Station No. 209 (Watsonville West II), and no irrigation between November and March to account for a typical rainy season. Based on the preliminary estimates, the preliminary water use factor for irrigation is approximately 1.8 acre-feet/acre. As reference, Wolcott (1999) used a similar factor of 1.7 acre-feet/acre.

Estimates by Kennedy (2015) for water use are also shown in Table 6 with notes where there are discrepancies from the preliminary estimates calculated based on the assumptions above.

| Institution/ Facility | Year | Area of Irrigated Turf (acres)Preliminary Outdoor Water | | Kennedy Estimates of Total Water Pumped (AFY)/Comments on Current Status | | |
|--|-------------------|--|-------------------|--|--------------------------------|--|
| Aptos High School | | 2.2 | 4.01 | 9.3 ³ | 13.3 | |
| КОА | | - | | | 11 estimate | 26.7 - seems high |
| Monterey Bay Academy | 2015 | uncertain | 577 ⁸ | 18 ³ | 5956 | |
| Renaissance High School | | 1.8 | 3.21 | 2.0 ³ | 5.3 | 1.7 |
| 7 th Day Adventist Conference* | | - | - | 8.0 ² | 8.0 | 11.0 / County confirms no current irrigation |
| Cabrillo College* | 2014 | 12.7 | 22.91 | 55.1 | 78.0^{6} | 95 |
| Enchanted Valley* | | - | - | 5.42 | 5.4 | 5 (rounded down) |
| Kennolyn Camp* | | | - | | on-municipal water estimate | 9 |
| Land of Medicine Buddha* | | - | - | 1.72 | 1.7 | 2 (rounded up) |
| Mountain Elementary School* | | 1.9 | 3.51 | 1.51 | 5.0 | County has 0.02AFY reported pumping – this seems low given they irrigate turf |
| Seascape Golf Course* | | 136.1 | 1086 | MS | 1086 | 232 / County permit for 108 AFY |
| Seascape Greens* | | 11.5 | 20.61 | MS | 20.6 | Not included |
| Soquel High School* | | 6.4 | 11.5 ¹ | MS | 11.5 | Not included |
| St. Clare's Retreat Home* | | - | - | 2 | 2 | Not included |
| Trout Gulch Mutual * | Ave 2008 –2014 | - | 20.47 | 47.57 | 67.95 | 67.1 |
| Total Model | | | | | 932.7 | |
| *Total Mid-County Groundwater Basin | | | | | 308.1 | |

Table 6: Estimated Groundwater Pumped by Institutions/Facilities in the Model Area

* = Mid-County Groundwater Basin

¹ Irrigated area multiplied by water use factor of 1.8 acre-feet/acre

³ Using per capita rates and other assumptions for schools from Wolcott (1999) Appendix E

⁵ Trout Gulch Mutual's pumping records ⁶ Santa Cruz County records

⁸ Difference between groundwater pumped and indoor use

MS = municipal supply

² Wolcott (1999) Appendix E

⁴ HydroMetrics (2015)

⁷ Based on 30/70 Outdoor/Indoor usage

Santa Cruz Mid-County Basin Groundwater Model Water Use Estimates and Return Flow Implementation

Page 15



Figure 2: Non-Municipal Groundwater Use Institutions

HydroMetrics Water Resources Inc. • 1814 *Franklin Street, Suite 501* • Oakland, CA 94612 (510) 903-0458 • (510) 903-0468 (fax)

4.0 AGRICULTURAL WATER USE

4.1 AGRICULTURAL IRRIGATION USE METHODOLOGY

An estimate of the amount of agricultural irrigation applied in the groundwater model is estimated based on crop evapotranspiration (ET_c). The amount of groundwater pumped for agricultural use will be estimated based on potential evapotranspiration (PET) minus rainfall evapotranspiration calculated by an initial simulation of watershed processes by PRMS that accounts for climatic conditions during the 1985-2015 model period as described in the previous section. For agriculture, crop coefficient (K_c) is affected by crop type, stage of growth, soil moisture, the health of the plants, and cultural practices. Values for K_c (unitless) are primarily those used in the PVWMA groundwater model developed by the USGS (Hanson *et al.*, 2014). Exceptions to Pajaro Valley K_c are coefficients for apple orchards, vineyards, pastures, and nurseries/greenhouses.

Apple orchards within the Mid-County Groundwater Basin are mostly well-established and require limited irrigation. We assumed only irrigation in the warmer months of April through October. The Pajaro Valley model April through October K_c values were reduced until the annual water demand approximated measured water use used in the CWD model for apple orchards (HydroMetrics WRI and Kennedy/Jenks, 2014). This same approach of reducing monthly K_c based on measured water use for the CWD model was taken for all vineyards (irrigated April through September) and pastures (irrigated April through November) in the model. The Pajaro Valley model used a K_c value of 0.1 for all 12 months for nurseries/greenhouses. A review of published papers on crop coefficients indicated that the coefficient should be much higher. Therefore we have assumed a K_c of 0.8 for all months for nurseries/greenhouses. The monthly K_c to be used in the GSFLOW model for each crop type are summarized in Table 7.

| Crop | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|---------------------------------|------|------|------|-------|-------|------|-------|------|------|-------|------|------|
| Turf (Urban) | 0.56 | 0.56 | 0.56 | 0.73 | 0.73 | 0.73 | 0.73 | 0.7 | 0.62 | 0.56 | 0.56 | 0.56 |
| Vegetable Row Crops | 0.61 | 0.61 | 0.61 | 0.92 | 0.71 | 0.6 | 1.04 | 0.92 | 0.59 | 1 | 0.85 | 0.61 |
| Strawberry | 0.62 | 0.62 | 0.62 | 0.86 | 0.66 | 0.58 | 1.01 | 0.9 | 0.56 | 1.06 | 0.86 | 0.62 |
| MGB Deciduous (Orchards) | 0 | 0 | 0 | 0.025 | 0.075 | 0.1 | 0.125 | 0.15 | 0.15 | 0.025 | 0 | 0 |
| Non-MGB Deciduous (Orchards) | 0.03 | 0.03 | 0.03 | 0.1 | 0.3 | 0.4 | 0.5 | 0.6 | 0.6 | 0.1 | 0.03 | 0.03 |
| Subtropical | 0.56 | 0.56 | 0.56 | 0.65 | 0.65 | 0.65 | 0.65 | 0.65 | 0.65 | 0.65 | 0.65 | 0.56 |
| Vines/Grapes | 0 | 0 | 0 | 0.17 | 0.22 | 0.23 | 0.23 | 0.22 | 0.12 | 0 | 0 | 0 |
| Pasture | 0 | 0 | 0 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0 |
| Grains (Field Crops) | 0.25 | 0.25 | 0.25 | 1.17 | 0.87 | 0.17 | 0.17 | 0.17 | 0.17 | 0.17 | 0.17 | 0.25 |
| Nurseries/Greenhouses | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 |

Table 7: Monthly Crop Coefficients (K_c)

| Crop | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|--|------|------|------|------|------|------|------|------|------|------|------|------|
| Raspberries/ Blackberries/Blueberries | 0.16 | 0.16 | 0.16 | 0.51 | 0.75 | 0.78 | 0.78 | 0.75 | 0.45 | 0.25 | 0.2 | 0.16 |
| Semi-agriculture | 0.31 | 0.31 | 0.31 | 0.62 | 0.74 | 0.7 | 0.7 | 0.53 | 0.34 | 0.27 | 0.27 | 0.31 |

Coefficients are unitless

Sources of data: PVWMA Groundwater Model (Hanson et al., 2014) and HydroMetrics WRI & Kennedy/Jenks (2014)

There are some apple orchards and pastures in the model that have been identified by the County as dry farmed and therefore no irrigation demand is estimated for those areas.

Annual agricultural demand is estimated by summing the product of the monthly crop coefficients (K_c), a monthly reference evapotranspiration (ET_o) that is measured at a nearby CIMIS station, and the crop acreage:

Agricultural Demand (acre – feet) = K_c (unitless) × ET_o (feet) × crop area (acres)

4.2 PRELIMINARY AGRICULTURAL IRRIGATION DEMAND ESTIMATE

Using the methodology described in the section above, Table 8 summarizes the crops, their 2014 acreages, and preliminary estimates for water demand for 2014 based on monthly reference crop evapotranspiration (ET_o) in 2014 from CIMIS Station No. 209 (Watsonville West II. The acreages and locations of crops were obtained primarily from PVWMA, which maps crop coverages at least annually. Current aerial photographs were used to supplement crop locations and types in areas to the west of the data provided by PVWMA. The County also provided some field verification and identified some areas within the Mid-County Groundwater Basin that are dry farmed.

The locations of horse and cattle related operations were identified through an internet search and confirmed by aerial photographs. Figure 3 shows the 2014 distribution of crops by type within the model area. Some of the agricultural demand in the model area is met by water supplied by CWD, as indicated in Table 8.

For the water demand from livestock related agriculture, horses are estimated by head count instead of acreage. It was assumed that horse boarding, breeding, and training facilities use 30 gallons per horse per day². The number of horses at each facility was estimated by counting the number of stalls from aerial photographs. The one cattle ranch that we have identified has been excluded because it appears small based on aerial photographs. Water use data for the one egg ranch within the model area was provided by CWD.

² Horses require on average 10 gallons per day for direct consumption. We assumed 20 gallons per day per horse additional water use for other activities at the facility such as cleaning and dust control. Assuming 35 horses, a total water use of 30 gallons per day per head is also the Barn Boarding Stable's 2005-2015 average metered records from CWD.

| Crop/Activity | Unirrigated Acreage (acres) | | Irrigated Acreage (acres) | | Estimated 2014 Water Demand by Supply (AFY) | | Estimated 2014 Water Demand by Area (AFY) | |
|---|--------------------------------|------------------------------------|------------------------------|------------------------------------|---|---------------|---|------------------------------------|
| 1 7 | Model Area | Mid-County Groundwater Basin | Model Area | Mid-County Groundwater Basin | Private Supply | CWD Supply | Model Area | Mid-County Groundwater Basin |
| Deciduous (Apple Orchards) | 89 | 89 | 1,515 | 350 | 1,185 | 10 | 1,195 | 81 |
| Strawberries | - | - | 653 | 0 | 1,706 | 0 | 1,706 | 0 |
| Vegetable Row Crop | - | - | 652 | 88 | 1,705 | 33 | 1,738 | 235 |
| Nurseries/Flowers/Tropical Plants | - | - | 566 | 27 | 1,555 | 0 | 1,555 | 74 |
| Raspberries and Blackberries | - | - | 520 | 0 | 912 | 0 | 912 | 0 |
| Vine/Grapes | - | - | 280 | 186 | 115 | 10 | 125 | 83 |
| Fallow | - | - | 206 | 0 | 0 | 0 | 0 | 0 |
| Pasture | 33 | 33 | 205 | 74 | 440 | 0 | 440 | 160 |
| Greenhouse | - | - | 75 | 3 | 206 | 0 | 206 | 8 |
| Other Agriculture | - | - | 31 | 0 | 54 | 0 | 54 | 0 |
| Bamboo | - | - | 30 | 30 | 0 | 13 | 13 | 13 |
| Ag. Unknown | - | - | 4 | 1 | 6 | 0 | 6 | 3 |
| Olive Orchard (similar to apple orchard demand) | - | - | 1 | 1 | 0 | 0.2 | 0.2 | 0.2 |
| Citrus | - | - | 22 | 22 | 48 | 0 | 48 | 48 |
| Horses | - | - | - | - | 13.7 | 0.3 | 14 | 7 |
| Egg Ranch | - | - | - | - | 0 | 2 | 2 | 2 |
| Total Crops and Livestock | 122 | 122 | 4,759 | 784 | 7,946 | 69 | 8,015 | 715 |

Table 8: Summary of 2014 Agricultural Water Demand

Santa Cruz Mid-County Basin Groundwater Model Water Use Estimates and Return Flow Implementation

Page 19



Figure 3: 2014 Agriculture in the Model Area

HydroMetrics Water Resources Inc. • 1814 *Franklin Street, Suite 501* • Oakland, CA 94612 (510) 903-0458 • (510) 903-0468 (fax)

5.0 IMPLEMENTING NON-MUNICIPAL PUMPING IN MODEL

All non-municipal domestic and institutional, and agricultural water use is assumed to be supplied by privately pumped groundwater. This pumping will be aggregated and estimated for each applicable model cell; specific wells will not be explicitly simulated in the model. The pumping estimates will be added to the Multi-Node Well (MNW2) package file as multi-layer wells screened from the top layer to the lowest likely layer of production for the grid cell. Pumping will be distributed to layers by the model based on simulated layer transmissivity. If the shallowest layers become dry in the model, pumping is distributed to lower saturated layers so that all of the estimated pumping is included in the model's water budget.

6.0 SIMULATING RETURN FLOW COMPONENTS

There are a number of return flow components that will be included in the groundwater model. This memorandum introduces these components and how we propose to estimate them. The final estimates and resultant model input will be discussed in the memorandum documenting the integrated GSFLOW model.

In general, return flow components include:

- 1. System losses: water, sewer and septic systems,
- 2. The inefficient portion of municipal and non-municipal domestic and institutional irrigation (outdoor applied water), and
- 3. The inefficient portion of agricultural irrigation.

A phased approach is planned for implementing return flow components in the GSFLOW model. Initially, all return flow components will be added in GSFLOW's UZF package, which is applied below the root zone (Table 9). The US Geological Survey recently added this capability to UZF under its joint funding agreement with SqCWD. Using only the single package that is integral to GSFLOW will expedite model results that will allow MGA and members evaluate groundwater management alternatives and supplemental supply options by early 2017. However, adding return flow components to UZF will preclude calculation of near surface runoff of the return flow components to surface water.

Future work will continue use of UZF for simulating return flow from water and sewer system losses, and septic systems, which is assumed to occur below the soil root zone. However, there is an option to simulate return flow from the inefficient portions of irrigation using the newly developed Water Use Module (WUM) for PRMS, which adds water to the near surface capillary zone (Table 9). This module effectively allows for the inefficient

portions of return flow near surface runoff to surface water as well as groundwater recharge. The need to implement WUM will be evaluated in 2017 when the model will be used to analyze relative impacts from various water use classifications under a County Proposition 1 grant.

| | Package used in Model Implementation | | | |
|--------------------------------------|--------------------------------------|----------------------|--|--|
| Return Flow Component | Initial (2016) | Future Option (2017) | | |
| Water system losses | UZF | UZF | | |
| Sewer losses | UZF | UZF | | |
| Septic system losses | UZF | UZF | | |
| Municipal & non-municipal irrigation | UZF | WUM | | |
| Agricultural irrigation | UZF | WUM | | |

 Table 9: Summary of Packages Used to Simulate Return Flow in the Model

The following sections describe our proposed approach for simulating the different return flow components using UZF only for this first phase of return flow implementation.

6.1 WATER SYSTEM LOSSES

Water system losses will be calculated as percentage of estimated deliveries to each service area and applied in UZF to model cells overlying those service areas.

For the Central Water District (CWD) model, the system loss percentage for CWD was varied over time based on unaccounted water losses by fiscal year through 2009 (HydroMetrics WRI and Kennedy/Jenks, 2014). The approximate range of CWD system loss estimated for the CWD model for 1984-2009 was 4-14%. This percentage will be updated for fiscal years through 2015.

For the CWD model, the system loss percentage for Soquel Creek Water District (SqCWD) was estimated as 7% which was confirmed through a SqCWD water audit for 2010-2013 (Mead, 2014). The Cities of Santa Cruz and Watsonville water system losses will be 7.5% and 6%, respectively, per their 2015 Urban Water Management Plans (UWMP)

6.2 WASTEWATER RETURN FLOWS

Wastewater return flows will be based on indoor use that becomes wastewater. Indoor use has generally been assumed to be 70% of total water use (Johnson et al., 2004 and USEPA, 2008) and 90% of indoor water use is assumed to become wastewater. There are a range of available estimates for this value with measurements at mountain residences in Colorado

indicating approximately 81% (Stennard et al, 2010) and California Department of Water Resources (1983) estimating 98%.

For wastewater return flows from sewer losses in sewered areas, the same loss percentage of 7% used in the CWD model based on the SqCWD system loss percentage will be applied to model cells overlying all sewered areas. These sewer losses will be added in UZF to infiltrate below the root zone.

All of indoor water use that becomes wastewater for septic systems will be also be added in UZF below the root zone for model cells in unsewered areas. Although there has been research indicating additional evapotranspiration from septic systems than surrounding areas (Stannard et al., 2010), typical leachfield depth in Santa Cruz County is 4 to 50 feet and County staff has rarely observed increased vegetation overlying or nearby leachfields that would indicate root zone evapotransporation from septic systems (Ricker, 2016).

Santa Cruz County has observed that the percentage of indoor use is influenced by overall water use and climatic conditions (Ricker, personal communication). In years of drought, such as from 2013 – 2015, water conservation is practiced to a greater extent by the public. Outdoor use is usually the first place where water use is cut, thus the percentage of indoor use is greater in those years than years when the overall water use is higher. For the period through 2013, the percentage of indoor use in the model will be 70% and will increase to 75% for 2014, and to 80% for 2015.

6.3 IRRIGATION RETURN FLOWS

The portion of water from irrigation that returns to the watershed as runoff or groundwater recharge is the inefficient portion of irrigation. The amount of water applied in UZF is just the inefficient irrigation calculated in the model cell because UZF represents what is below the capillary zone where the crop's evapotranspiration demand is met. The inefficiency factor, or the percentage of crop ET demand that does not evapotranspirate, will range from 10% (Todd, 2014) to 20% (Johnson et al., 2004).

7.0 CALCULATING RETURN FLOW COMPONENTS

Calculation of return flow components depends on water source and wastewater destination in addition to type of water use. The following sections describe our proposed approach for calculating the different return flow components.

7.1 MUNICIPAL RETURN FLOW

Figure 4 illustrates how we plan to estimate return flows from municipally supplied water including system losses and wastewater return flows discussed above as well as irrigation return flows. From available water supply records, we will distribute return flows spatially based on land use and service areas. Municipal water use for the Cities of Santa Cruz and Watsonville includes both surface water and groundwater. Land use factors affecting municipal return flow include defining areas of large-scale irrigation versus primarily residential and commercial use where irrigation is at a smaller scale. Figure 5 shows the locations of municipal service areas and various land use categories used for different applied water types.

To estimate the amount of residential and commercial water use for each municipal service area, water system losses as described above and water used for large-scale irrigation will be subtracted from the amount of water supplied to each service area. The amount of irrigation applied will vary monthly based on local potential evapotranspiration (Figure 4). Return flow comprised of the inefficient portion of outdoor use, sewer losses in sewered areas, and septic system leakage will be distributed to model cells overlying those service areas. Areas that are not supplied water, such as open space and undeveloped land will be excluded.



Service Area Pumping +/- Transfers

Figure 4: Approach to Estimating Municipal Return Flow



Figure 5: Municipal Applied Water Areas HydroMetrics Water Resources Inc. • 1814 Franklin Street, Suite 501 • Oakland, CA 94612 (510) 903-0458 • (510) 903-0468 (fax)

Return flow represented by the inefficient portion of large-scale irrigation of sports fields and parks will also be applied to model cells that overlie those irrigated areas. Estimates of large-scale irrigation will rely on irrigation demand as estimated by the difference between capillary zone PET and actual rainfall ET simulated by PRMS, the area of the cell being irrigated, a crop factor, and irrigation inefficiency.

7.2 NON-MUNICIPAL DOMESTIC RETURN FLOW

The inefficient portion of non-municipal outdoor domestic use will be applied in the model using the non-municipal domestic water use described earlier in this technical memorandum. Figure 6 shows approximately 30% of total domestic water use will be assumed for outdoor use based on the average outdoor water use for 1985-2013, and a portion of this outdoor use, based on an inefficiency factor, will be applied to cells overlying the areas identified in this memo as having nonmunicipal domestic water use. The percentage of outdoor water use is assumed to decrease for 2014-2015 to achieve recent conservation as described in Section 6.2, and will vary monthly to simulate changing seasonal demands. Figure 6 also shows the wastewater return flow of indoor use from septic systems as described above.



Figure 6: Approach for Estimating Non-Municipal Domestic Return Flow

7.3 INSTITUTIONAL NON-MUNICIPAL IRRIGATION RETURN FLOW

Similar to municipal large-scale irrigation, the inefficient portion of municipal institutional irrigation will be applied to model cells that overlie institutional irrigated areas (Figure 2), and will represent a proportion of applied water based on an assumed inefficiency factor. The calculation of return flow for each model cell is shown in Figure 7.

7.4 AGRICULTURAL IRRIGATION RETURN FLOW

The inefficient portion of agricultural irrigation to apply in the model will be based on the difference between PRMS estimated PET and actual ET (irrigation demand), the area of the cell being irrigated, a specific crop factor, and irrigation inefficiency (Figure 7). Santa Cruz Mid-County Basin Groundwater Model Water Use Estimates and Return Flow Implementation



Page 26

potet = PRMS Estimates Potential ET actet = PRMS Estimates Actual ET

Figure 7: Return Flow Estimate Approach from Irrigation per Model Cell

8.0 SENSITIVITY OF WATER USE AND RETURN FLOW ASSUMPTIONS

This technical memorandum describes a number of assumptions for water use and return flow that will be incorporated into the Mid-County Groundwater Basin groundwater model. These assumptions can be tested with sensitivity runs using the model that test the effect of changing the assumptions on model predictions. However, when making any changes, the model calibration to groundwater level data and streamflow must be checked and the model potentially will need to be re-calibrated based on the changes. Only a calibrated model should be used to assess changes to model predictions.

9.0 REFERENCES

- Bracamonte, R. 2016. Email RE: private water use estimates for model. April 19.
- California Department of Water Resources. 1983. Urban water use in California. Bulletin 166-3.
- City of Santa Cruz, 2016. 2015 Urban Water Management Plan. August.
- City of Watsonville, 2016. 2015 Urban Water Management Plan. June.
- Hanson, R. T., Wolfgang Schmid, Claudia C. Faunt, Jonathan Lear, and Brian Lockwood. 2014. Integrated Hydrologic Model of the Pajaro Valley, Santa Cruz and Monterey Counties, California. USGS Scientific Investigations Report 2014-5111.
- HydroMetrics WRI and Kennedy/Jenks. 2014. Aromas and Purisima Basin Management Technical Study, Santa Cruz Integrated Regional Water Management Planning Grant Task 4. Prepared for Central Water District. March.
- Johnson et al. 2004. Groundwater Assessment of Alternative Conjunctive Use Scenarios Technical Memorandum 2: Hydrogeologic Conceptual Model. Prepared for Soquel Creek Water District. September.
- Kennedy, J. 2015. SCWD Private Wells Survey List, version 10.
- Mead, C. 2014. Staff Memo for Board of Directions Item 3.17 Annual Water Audit. March 18.
- Pingree, R.H. 1998. Groundwater Consumption Analysis of Private Wells within the Aquifers of the Soquel Creek Water District. DRAFT. Soquel Creek Water District. May 28.
- Pajaro Valley Water Management Agency (PVWMA). 2010. Proposition 218 Service Charge Study.
- Ricker, J. 2016. Email RE: septic system regulations. January 11.
- Ricker, J. 2016. Personal communication re: rural outdoor water use. October 11.
- Stannard, D.I., W.T. Paul, R. Laws, and E.P. Poeter. 2010. Consumptive use and resulting leach-field water budget of a mountain residence. Journal of Hydrology 388. July.
- Todd Groundwater. 2014. Peer Review of Technical Water Resources Studies. Technical Memorandum to Kim Adamson and Taj Dufour, Soquel Creek Water District. July 8.

- USEPA 2008. Indoor Water Use in the United States. EPA Water Sense EPA-832-F-06-004, June.
- Wolcott, J. 1999. Methodology of calculating water use in the Purisima Aquifer. Santa Cruz County Environmental Health Services. October 29.

Appendix A

List of Santa Cruz County land use codes used to identify non-municipal water use residential parcels. Those in bold are codes that did not contain residential building footprints.

010-LOT/RESIDENTIAL ZONE 015-LOT/MISC RES IMPS 016-BUILDING IN PROGRESS 020-SINGLE RESIDENCE 021-CONDOMINIUM UNIT 023-NON-CONFORMING RES 024-SFR W/ SECONDARY USE 025-AFFORDABLE HOUSING 027-TOWNHOUSE 028-SFR + SECOND UNIT 029-SFR + GRANNY UNIT 030-SINGLE DUPLEX 031-TWO SFRS/1 APN 032-3 OR 4 UNITS/2+ BLDGS 033-TRIPLEX 034-FOUR-PLEX 040-VACANT APARTMENT LOT 041-5 - 10 UNITS 042-11 - 20 UNITS 043-21 - 40 UNITS 044-41 - 60 UNITS 045-60 - 100 UNITS 046-OVER 100 UNITS 050-LOT/RURAL ZONE 051-1-4.9 ACRE/RURAL 052-5-19.9 ACRE/RURAL 053-20- 49.9 ACRE/RURAL 054-50- 99.9 ACRE/RURAL 055-100-199.9 ACRE/RURAL 05B-MISC IMPS 1-4.9 ACRE 05C-MISC IMPS 5-19.9 ACRE 05D-MISC IMPS 20-49.9 ACRE 05F-MISC IMPS 100-199.9 ACR

HydroMetrics Water Resources Inc. • 1814 *Franklin Street, Suite 501* • Oakland, CA 94612 (510) 903-0458 • (510) 903-0468 (fax)

060-HOMESITE/<1 ACRE 061-HOMESITE/1-4.9 ACRES 062-HOMESITE/5-19.9 ACRE 063-HOMESITE/20-49.9 ACRES 064-HOMESITE/50-99.9 ACRES 065-HOMESITE/100-199.99 ACRE 068-RURAL DWELLINGS/1 APN 070-MOTEL/UNDER 20 UNITS 071-MOTEL/20 TO 49 UNITS 072-MOTEL/50 + UNITS 074-RESORT MOTEL 080-HOTEL 085-BED AND BREAKFAST 262-NURSERY W/ RES 411-ORCHARD/RESIDENCE 421-VINEYARD/RESIDENCE 431-BERRY FARM/RESIDENCE 432-BERRY FARM/MISC IMPS **451-VEGIE FARM/RESIDENCE** 480-POULTRY RANCH 490-DIVERSIFIED FARM 500-TPZ/NO RESIDENCE 501-TPZ/RESIDENCE 511-CLCA/RESIDENCE 520-OSE/NO RESIDENCE 521-OSE/RESIDENCE 711-OTHER CHURCH PROPERTY